



Notes:

1. The pedestal cannot be used for other customer wires such as a feeder out to the garage NEC 230.7.
2. All meter pedestals must be ringless, have minimum of horn bypass, be sealable, and be UL Listed.
3. Only pedestals are allowed for underground because of frost heave problems.

200 amp Single Phase UG Pedestals

Possible acceptable catalog numbers. Need one extension for UPPCo. Extensions only needed in WPSC if required for height reasons.

MILBANK	U3358-0-KK	ext. K5800 (15")
SQUARE D	UHT-RP2423-63-SQD	ext. 1007680-SQD (18") or 1008786-SQD (30")
CUTLER HAMMER	UHT-RP2423-63-CH	ext. 1007680-CH (18") or 1008786-CH (30")
MIDWEST	UHT-RP2423-63-MEP	ext. 1007680-MEP (18") or 1008786-MEP (30")
LANDIS & GYR (Siemens)	UAP317-PPWI	ext. 5007718
DURHAM	UHT-RP2423-63	ext. 1007680 (18") or 1008786 (30")

DIGGERS 811

Revised: 03/10