



200 amp Single Phase UG Pedestal with 4-6 Position Main Disconnect

Possible acceptable catalog numbers. Need an extension for UPPCo. Extension only needed for WPSC if required for height reasons.

| | | |
|---------------|-------------------------------|---|
| MILBANK | NU8980-0-KK | no extension available |
| | U5136-0-Series | no extension available |
| CUTLER HAMMER | 1008846-CH | ext. 1009021-CH (18") or 1009024-CH (30") |
| Durham | 1008846 or 1009078 or 1008961 | ext. 1009021 (18:) or 1009024 (30") |

1. Must be attached to support post if free standing. Use a minimum of 8 foot, pressure treated 6X6 or 4X6. This must be buried at least 48 inches with a 16 inch treated 2X6 for a base.
2. This is commonly used if the service entrance conductor extends into the building longer than permitted by WI COMM 16.230(3) (8 foot rule) or by NEC 230.70(A) for MI. It is also acceptable to use a standard pedestal (page 2-2) and use a separate weatherproof disconnect.

Revised: 03/10

WPSC/UPPCO SERVICE MANUAL

100-200 AMP SINGLE PHASE UG WITH MAIN

2-3