



Mobile Home Requirements

- A. An approved mobile home connector is required between the meter set and home. This connector must not pass through the skirting. Contact a plumbing or heating dealer for installation (NFPA 501A Part 4.4.1).
- B. Furnaces and water heaters must have name plate stating: "Approved for mobile or manufactured home installation." The Company cannot provide gas to a water heater or furnace if not listed for installation in a mobile home (ANSI Code Z21.47 and Z21.10.1 (NFPA paragraph 10.30)).

Flexible CSST has not been approved as an acceptable joining material to a meter set on a mobile home, as governed by HUD.

Per standard for mfg. home installations NFPA - 501A.

Revised: 03/10