



Upper Peninsula Power Company

Appendix A

UPPCO Meter Base Requirements

1. 100-200 Amp Single-Phase UG
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. Outdoor Enclosure (Nema type 3R)
 - c. 1 Phase, 3-Wire
 - d. 4 Jaw Meter Socket
 - e. Horn Bypass
 - f. Sealable
 - g. No cover over meter
 - h. UL Listed
 - Options:
 - Schneider Electric
 - UHT-RP2423-63
 - Extension: 1007680 (18") or 1008786 (30")
 - Available at Standard Electric
 - Cutler Hammer
 - UHT-RP2423-63-CH
 - Extension: 1007680-CH (18") or 1008786-CH (30")
 - Available at Menards
 - Midwest
 - UHT-RP2423-63-MEP
 - Extension: 1007680-MEP (18") or 1008786-MEP (30")
 - Landis & Gyr (Siemens)
 - UAP317-PPWI
 - Extension: 18" kit = 5007726 30" kit = 5007727
 - Millbank
 - U3358-0-KK
 - Extension: 15" K5800
 - Available at Westphal Electric

2. 100-200 Amp Single-Phase UG with Main
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. Outdoor Enclosure (Nema type 3R)
 - c. 1 Phase, 3-Wire
 - d. 4 Jaw Meter Socket
 - e. Horn Bypass
 - f. Sealable
 - g. No cover over meter
 - h. UL Listed
 - Options:
 - Milbank
 - NU8980
 - K3701 connector block required to replace breaker
 - U3358-O-KK
 - K3082 set screw connector kit required.
 - U5925-O-200-KK
 - Meter main with load center
 - Cutler Hammer
 - 1008846-CH
 - Extension: 1009021-CH (18") or 1009024-CH (30")
 - Available at Wesco
 - Eaton
 - MHR100P Series
 - MHR100P Series Extension: CHPPEXT100
 - MHR200P Series
 - MHR200P Series Extension: MHPEDEXT
 - MHR200P1MMBPH (Main breaker and 8 spaces)
 - Make sure to install the locking mechanism
 - Available at Menards & All-Phase
 - Siemens (Main breaker and 20 space circuit)
 - MC2040B1200RJBC (add extension)
 - Available at Home Depot

3. 100-200 Amp Single-Phase OH
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. Outdoor Enclosure (Nema type 3R)
 - c. 1 Phase, 3-Wire
 - d. 4 Jaw Meter Socket
 - e. Horn Bypass
 - f. Sealable
 - g. No cover over meter
 - h. UL Listed
 - The Company has no list of approved sockets for this application. The meter base shall meet the requirement above and be securely mounted. NEC 110.13(A)

4. Multi-occupancy dwelling
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. Outdoor Enclosure (Nema type 3R)
 - c. 1 Phase, 3-Wire
 - d. 4 Jaw Meter Socket
 - e. Horn Bypass
 - f. Sealable
 - g. No cover over meter
 - h. UL Listed
 - Options:
 - Siemens
 - WP6412 Uni-Pak (1ph - 120/240, 600a)
 1. Available at Menards
 - Square D
 - EZ Meter Pak series -
 1. EZM31600GCBU (3ph – 120/208, 1600a)
 2. EZMH113125 (1ph - 120/240, 125a)
 3. EZML112225 (1ph – 120/240, 225a)
 4. EZM1800TB (800a terminal box)
 5. Available at Graybar


5. 320 Class / 400 Amp Single-Phase OH
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. 4 Jaw Meter Socket
 - c. 320A Continuous, 400A Max
 - d. Outdoor Enclosure (Nema type 3R)
 - e. Bypass Lever
 - f. Rated 600V AC
 - g. Sealable
 - h. 1 Phase, 3-Wire
 - i. No cover over meter
 - j. UL Listed

- The Company has no list of approved sockets for this application. The meter base shall meet the requirement above and be securely mounted. NEC 110.13(A)
- 6. 320 Class / 400 Amp Single-Phase UG
 - Requirements:
 - a. Ringless Type Meter Socket
 - b. 320A Continuous, 400A Max
 - c. Rated 600V AC
 - d. Outdoor Enclosure (Nema type 3R)
 - e. 1 Phase, 3-Wire
 - f. 4 Jaw Meter Socket
 - g. Bypass Lever
 - h. Sealable
 - i. No cover over meter
 - j. UL Listed
 - Options
 - Milbank
 - U1748-O-WI
 - U4363XQGK3K2
 - Extension: S1848
 - Available at All-Phase
 - Schneider Electric
 - 1009018
 - Extension: 1009023 (18") or 1009026 (30")
 - Cutler Hammer
 - 1009018-CH
 - Extension: 1009023-CH (18") or 1009026-CH (30")
 - Available at Menards
 - Midwest
 - 1009018-MEP
 - Extension: 1009023-MEP (18") or 1009026-MEP (30")
 - Durham
 - 1009018
 - Extension: 1009023 (18") or 1009026 (30")
 - Landis & Gyr
 - 47604P-9WI


7. 320 Class / 400 Amp Single-Phase UG with two 200A Main Breakers

- Requirements:
 - a. Ringless Type Meter Socket
 - b. 4 Jaw Meter Socket
 - c. 320A Continuous, 400A Max
 - d. Bypass Lever
 - e. Rated 600V AC
 - f. Sealable
 - g. 1 Phase, 3-Wire
 - h. UL Listed
- Options
 - Durham
 - 1009017
 - Extension: 1009022 (18") or 1009025 (30")
 - Cutler Hammer
 - 1009017-CH
 - Extension: 1009022-CH (18") or 1009025-CH (30")
 - Available at Menards
 - Milbank
 - U3849-0-2/200
 - (no extension available)
 - Available at All-Phase

Examples:



Horned Bypass (100-200A requirement)
5 jaw network meter socket



Horned Bypass (100-200A requirement)

